

# Contra Costa County



# Fire Protection District

MVD

F.D. Permit Number

Date

Description of Work: \_\_\_\_\_

Project Name: \_\_\_\_\_ Address: \_\_\_\_\_

Suite: \_\_\_\_\_ City: \_\_\_\_\_ Zip: \_\_\_\_\_

Contractor: \_\_\_\_\_ Contractor's License/Type #: \_\_\_\_\_

Address: \_\_\_\_\_ City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Contact Person: \_\_\_\_\_ Phone No. ( ): \_\_\_\_\_ Email: \_\_\_\_\_

**OFFICE USE ONLY: DO NOT COMPLETE BELOW THIS LINE**

We have reviewed the proposed **display of motor vehicles, including boats and motor craft** application. Our review is to ensure compliance with the minimum code requirements related to fire and life safety as set forth in the California Fire Code 2019 Edition. **All of the following requirements shall be adhered to:**

**INDOOR DISPLAYS (Liquid fueled/gaseous fueled)**

1. Batteries shall be disconnected except where the fire code official requires that the batteries remain connected to maintain safety features. (CFC 314.4 (1))
2. Vehicles shall not be fueled or defueled within the building. (CFC 314.4 (4))
3. Fuel in the fuel tank shall not exceed one-quarter of the tank or 5 gallons, whichever is less. (CFC 314.4 (2))
4. Fuel tanks and fill openings shall be closed and sealed to prevent tampering. (CFC 314.4 (3))
5. The location of vehicles shall not obstruct means of egress. (California Code of Regulations, Title 19, Division 1, 3.11 (a))

**INSIDE TENTS**

1. Fuel systems shall be inspected for leaks prior to parking vehicle within the facility. (CFC 3107.15.2.2)
2. Batteries shall be disconnected in an appropriate manner. (CFC 3107.15.1)
3. Vehicles or equipment shall not be fueled or defueled within tent or membrane structures. (3107.15.2)
4. Fuel in the fuel tank shall not exceed one-quarter of the tank or 5 gallons, whichever is less. (CFC 3107.15.2.1)
5. Fuel tank openings shall be locked and sealed to prevent the escape of vapors. (CFC 3107.15.2.3)
6. The location of vehicles shall not obstruct means of egress. (CFC 3107.15.3)
7. Fuel for vehicles shall be stored in approved containers in an approved location not less than 50 feet outside the structure. (CFC 3107.15.5.1 and 3107.14.2)
8. Refueling of the vehicle shall be performed outside the structure and not less than 20 feet from the tent or membrane structure. (CFC 3107.15.5.2 and 3107.14.3)

**This completed application shall be available on-site at the time of the final inspection.**

(CONTINUED OVER)

Fee computed by: \_\_\_\_\_ Amount Due: \$ \_\_\_\_\_

Received by: \_\_\_\_\_ Amount Received: \$ \_\_\_\_\_

Cash  Credit  Check No. \_\_\_\_\_ Invoice No. \_\_\_\_\_

